

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 7135-1501:141 Page 1 of 1

**CATEGORY:** Audible Signal Devices

**LISTEE:** \*Edwards Signaling, 90 Fieldstone Court, Cheshire, CT 06410  
Contact: David Mazur (203) 699-3000 Fax (203) 699-3100

**DESIGN:** Models 5533D-GR, 5533D-AW, 5533BD-AW, 5533BD-GR, 5534BD-AW, 5534BD-GR, 5534D-GR, 5534D-AW, CS2313, CS2313B, CS2314B and CS2314 combination horn/siren. Refer to listee's data sheet for detailed product description and operational considerations.

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model designation, electrical rating and UL label.

**APPROVAL:** Listed as audible devices for use with separately listed compatible control units. Models 5533D-GR, 5533D-AW, 5533BD-AW, 5533BD-GR, CS2313B and CS2313 are for use in hazardous locations, Class I, Groups B, C, and D. Models 5534D-GR, 5534D-AW, 5534BD-AW, 5534BDGR, CS2314B and CS2314 are for use in hazardous locations, Class I, Groups C, D and Class II, Groups E, F, and G.

If this appliance is required to produce a distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1999 Edition, the appliance must be used with a fire alarm control unit that can generate the temporal pattern signal. Refer to manufacturer's Installation Manual for details.

**NOTE:** Formerly 7135-1388:145, 7135-0073:147

\*Rev. 06-17-2003



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

**JUNE 17, 2003**

*Listing Expires **June 30, 2004***

Authorized By:

**DIANE K. AREND**, Senior Deputy  
Program Manager